



FULTON COUNTY PURCHASING DEPARTMENT
Winner 2000 – 2005 Achievement of Excellence in Procurement Award
National Association of Purchasing Management
Jerome Noble, Director

January 10, 2006

ADDENDUM NO. 3

Invitation to Bid Number
#05ITBR46701C-BL, 2006 Standby Miscellaneous Construction Waste Water System
Contract

Dear Vendors:

This addendum is in reference to **Invitation to Bid Numbers #05ITBR46701C-BL, 2006 Standby Miscellaneous Construction Waste Water System** in support of the Fulton County Public Works Department. This addendum provides additional information, requirements, terms and clarifications about this project.

- **All ductile iron pipe utilized in the Miscellaneous Construction Waste Water System bid is to be lined with Protecto 401 ceramic epoxy coating or an approved equal. If a product is bid that is equivalent to the Protecto 401 ceramic epoxy coating, then the bidder must provide written documentation to substantiate their claim of equivalency.**
- **The bid submission date has been extended from January 11, 2006 at 11:00 am local time to January 18, 2006 at 11:00 am local time.**

The undersigned proposer acknowledges receipt of this addendum by returning (1) copy with the proposal by the bid due date and time. Failure to include a signed copy of this addendum with your proposal documents could render your proposal non-responsive.

Except as provided herein, all terms and conditions in the ITB referenced above remain unchanged and in full force and effect.

Sincerely,

William E. Long, Jr.
Chief Assistant Purchasing Agent

ACKNOWLEDGMENT OF RECEIPT OF ADDENDUM NUMBER 3

COMPANY NAME: _____

SIGNATURE: _____

NAME: _____ TITLE: _____

DATE: _____