



Fulton County, GA

# Department of Purchasing & Contract Compliance

January 15, 2013

**Re: 13ITB85093C-DR, PREVENTIVE AND PREDICTIVE MAINTENANCE OF CHILLERS**

Dear Bidder(s):

Attached is one (1) copy of Addendum 2, hereby made a part of the above referenced **13ITB85093C-DR, PREVENTIVE AND PREDICTIVE MAINTENANCE OF CHILLERS.**

Except as provided herein, all terms and conditions in the 13ITB85093C-DR referenced above remain unchanged and in full force and effect.

Sincerely,

*Donald R. Riley*

**Donald R. Riley, CPPB  
Assistant Purchasing Agent**

Winner 2000 - 2009 Achievement of Excellence in Procurement Award • National Purchasing Institute



**13ITB85093C-DR, PREVENTIVE AND PREDICTIVE MAINTENANCE OF CHILLERS**  
**Addendum No. 2**  
**Page Two**

This Addendum forms a part of the contract documents and modifies the original RFP documents as noted below:

1. Attached hereto are responses to questions submitted in reference to the above RFP (i.e. Updated pricing section and chiller model numbers).

For additional information regarding this addendum, contact Donald R. Riley, CPPB, Assistant Purchasing Agent at (404) 612-7916. Except as provided herein, all terms and conditions in the bid referenced above remain unchanged and in full force and effect. Failure to return a signed copy of this addendum could render your bid non-responsive.

**ACKNOWLEDGEMENT OF ADDENDUM NO. 2**

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the proposal package to the Department of Purchasing & Contract Compliance, Fulton County Public Safety Building, 130 Peachtree Street, Suite 1168, Atlanta, Georgia 30303 by the RFP due date and time **January 16, 2013 at 11:00 A.M.**

This is to acknowledge receipt of Addendum No. 1, \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_.

\_\_\_\_\_  
Legal Name of Bidder

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Title

**QUESTIONS: 13ITB85093C-DR, PREVENTIVE AND PREDICTIVE  
MAINTENANCE OF CHILLERS**

Cooling Towers are part of the scope of work. Scope of work, Paragraph 7 deals with Cooling Towers.

Response: We have not sent out cooling tower info in the past.

## Location and Details of Cooling Towers

<b>Loc. No</b>	<b>Location</b>	<b>Make</b>	<b>Model #</b>	<b>SI. Number</b>	<b>Number of Fans</b>
1	Justice Tower, 185 Central Avenue	Marley	NC8407UAN4CGF	NC-10037082 A1-A4	4
2	Central Library, 1 Margaret Mitchell Square	Marley	NC 8402CC-11	10036764 A1	2
3	Main (Aldredge) Health Center, 99 Jesse Hill		N O T A V A I L A B L E		
4	Center for Health and Rehab, 265 Boulevard	Marley	AV61021	AV-247886-01	1
5	Judge Romae T Powell Juvenile Justice Center, 395 Pryor St	Marley	NC-221124-A1 & A2	NC8303FL2GS	2
6	College Park Regional Health Center, 1920 John Wesley Ave.	Evapco	1CT4-79	960404	2
7	South Fulton Multi-Purpose Center, 4255 Will Lee Road	Evapco	PMTA 10-122	953163	2
8	South Fulton Service Center, 5600 Stonewall Tell Road	Marley	B22156A/4862	89053	1
9	North Fulton Service Center, 7741 Roswell Rd.	Marley	B22156A/4862	89052	1
10	Jefferson Place Homeless Shelter, 1135 Jefferson St., NW	Frigidcoil	yec-11-525	43227a1	1
11	Government Center, 141 Pryor Street	NA	Sub-ground chamber and fans (2)	Gear equivalent to Model 110, 40 HP	AMARILLO  6:1 reduction

