



MAINTAIN 4' DEPTH TO AVOID
CONFLICT WITH OTHER UTILITIES

NOTES:

1. SERVICE LINE SHALL BE 3/4" DIAMETER FROM MAIN TO METER
2. USE ALL FLARE JOINTS
3. INSTALLATION SHALL ALLOW ADEQUATE ROOM TO REMOVE AND/OR REPAIR METER.
4. METER BOX SHALL BE APPROXIMATELY 12" x 18"
5. TYPE K COPPER SERVICE LINE MUST BE CONTINUOUS FROM METER TO MAIN
6. NEW WATER MAIN SUBJECT TO 250LB PRESSURE TEST FOR TWO HOURS.

FULTON COUNTY STANDARD DETAIL 801
3/4" & 5/8" METER INSTALLATION

DATE	REVISIONS	DATE	REVISIONS
8/08	NRR		

DOS/DRN/CHKD: CMS
APPROVED: _____
DATE: 12-2-05



FULTON COUNTY PUBLIC WORKS
141 PRYOR ST. ATLANTA, GA. 30303
404-612-7400 FAX: 404-224-0498

DRAWING NO.
801