



\*FOR RESIDENTIAL ONLY.

NOTE REQUIRED:  
CONCRETE STRENGTH TEST REQUIRED  
FOR ALL Poured IN PLACE CONCRETE.

NOTES:  
SEE STANDARD 815 FOR UNCURED STREET.  
ALL VALVES MUST BE RATED AT WORKING PRESSURE OF 200 PSI  
AND TESTED AT A PRESSURE OF 250 PSI. ALL FIRE HYDRANTS  
MUST BE ACCOMPANIED BY A MANUFACTURERS CERTIFICATE THAT  
STATES EACH HYDRANT HAS BEEN TESTED AT AWWA  
SPECIFICATIONS C502-85 OR ANY LATER REVISION.

FULTON COUNTY STANDARD DETAIL 814  
HYDRANT LOCATION DETAIL FOR  
CURB & GUTTER STREETS

| DATE | REVISIONS | DATE | REVISIONS |
|------|-----------|------|-----------|
| 8/08 | NRR       |      |           |
|      |           |      |           |
|      |           |      |           |
|      |           |      |           |

DGS/DRN/CHKD: REB  
APPROVED: REW  
DATE: 12-2-05



FULTON COUNTY PUBLIC WORKS  
141 PRYOR ST. ATLANTA, GA. 30303  
404-612-7400 FAX: 404-224-0498

DRAWING NO.

814