



- NOTES:
1. NO POOLS STRUCTURES DECKS, BRIDGES OR PATIOS MAY BE PLACED IN THE PERM. EASEMENT.
 2. CLEAR ALL TREES IN PERM EASEMENT AND MAINTAIN CLEARANCE.
 3. RESEED, FERTILIZE AND MULCH ALL DISTURBED AREAS PER EROSION CONTROL STANDARDS, MAINTAIN 1% SLOPE DRAINAGE.
 4. NO PERMANENT STRUCTURES INSIDE PERMANENT EASEMENT.
 5. NO BURY PITS ALLOWED IN EASEMENT.

FULTON COUNTY STANDARD DETAIL 704
SANITARY SEWER EASEMENT

| DATE | REVISIONS | DATE | REVISIONS |
|------|-----------|------|-----------|
| 8/08 | NRR | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

DGS/DRN/CHKD: JM
 APPROVED: REW
 DATE: 12-2-05



FULTON COUNTY PUBLIC WORKS
 141 PRYOR ST. ATLANTA, GA. 30303
 404-612-7400 FAX: 404-224-0498

DRAWING NO.
704